

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Abhishek Chand Jain (AEN PHED Sub Div Kota)

(Name of Officers with designation) from Teachers colony PHED

inspected the BANSAL PUBLIC SCHOOL Ganesh Nagar - KOTA

(Name & Address of the school) on 16/12/2024 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. Lab. Tech (Chem.) 2024-25/579 dated 23/12/2024

of PHED Regional Lab, Akolgitth - KOTA (PHED Lab) certified that the

BANSAL PUBLIC SCHOOL - KOTA (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till June - 2025

Signature with Seal: Abhishek Jain  
Name : Abhishek Chand Jain  
Designation : AEN PHED Sub Div Kota  
Name & Address of the Office / Department : PHED Sub Div Kota

To  
Bansal Public School  
Ganesh Nagar, Near Medical College - KOTA  
(Name & Address of the Institution)

Abhishek Jain  
सहायक अभियंता  
जल: पत्र: अभि: विभाग  
जिला: जयपुर प्रख. कोटा  
दि. सं. 12827

Note: The certificate is to be issued by authorized officer / PHED Lab / local Bodies

# OFFICE OF THE SENIOR CHEMIST

Public Health Engineering Department, Regional Laboratory, Kota  
Test Report (Chemical Examination of Water)



No.Lab./Tech.(Chem)/2024-25/ 1590  
To,  
**Bansal Public School**  
**Ganesh Nagar, Kota**

Date- 23/12/24


District- Kota

Sample taken by- Mahendra Kumar Verma

Ref.No./ Date-N.M. Date 16.12.24  
Date of Receipt- 16.12.24

Sample Not Collected by Lab

Source	Permissible Value as per IS : 10500/2012		School Water Tap R.O.
			Location
			Bansal Public School Ganesh Nagar
Village/Town/City			Kota
Date of Collection			16.12.24
Date of Examination			18.12.24
Sample No	Desirable Limit	Permissible limit in absence of alternate Source	PC-193
Note:- All results except pH are in mg/L			
pH	6.5 to 8.5	No relaxation	7.80
Turbidity(NTU)	1	5	0.67
Colour	5	15	-
Odour	Agreeable	Agreeable	-
Total Alkalinity ( as CaCO <sub>3</sub> )	200	600	24
Total Hardness ( as CaCO <sub>3</sub> )	300	600	92
Chloride ( as Cl <sup>-</sup> )	250	1000	32
Nitrate ( as NO <sub>3</sub> <sup>-</sup> )	45	45	3
Fluoride ( as F <sup>-</sup> )	1.0	1.5	0.0070
Total Dissolved Solids	500	2000	136

  
Senior Chemist  
PHED Reg. Laboratory Kota

No.Lab./Tech.(Chem)/2024-25/  
Copy To :

Date:-

1. Chief Chemist, PHED Rajasthan, Gandhi Nagar, Jaipur

Senior Chemist  
PHED Reg. Laboratory Kota

**OFFICE OF THE SENIOR CHEMIST**  
**Public Health Engineering Department Regional Laboratory**  
**AKELGARH KOTA - 324010 (Raj.)**  
**BACTERIOLOGICAL EXAMINATION OF WATER**

PHED/Lab./Sr. Chemist/Bact./2024.2025. 1590

Date : 23/12/24

To,  
 The Bansal Public School,  
Ganesh Nagar,  
Kota,

Tehsil : Ladpura

District : Kota

Village : Kota


Reference N.M./16.12.24

Code No. : U

Name of Sample Taker Sh. Mahendra Kumar Verma

*Sample Not Collected by Lab*

Lab Sample Number	Date & Time of Collection	Date of Exam.	Residual Chlorine Mg/Lit.	Source	PARTICULARS OF SAMPLE	Coliform organism MPN/100 ML.	E coli organism MPN/100 ML.
PB-131	16-12-24	16-12-24 to 18-12-24	-	RO	Bansal Public School, Ganesh Nagar, <del>Kota</del>	Nil	

  
 Senior Chemist  
 P.H.E.D. Regional Lab. Kota

PHED/Lab./Sr. Chemist/Bact./2024.2025. ....

Date

- Copy to (1) S.E., P.H.E.D., Circle, Kota  
 (2) Ex. En. P.H.E.D., Div.....  
 (3) .....

Senior Chemist  
 P.H.E.D. Regional Lab. Kota