




कार्यालय नगर निगम कोटा दक्षिण (राज०)

क्रमांक :- ननिको(द.) / जनस्वा. / 2025 / 1121

दिनांक :- 6/3/25


प्रमाण-पत्र

प्रमाणित किया जाता है कि बंसल पब्लिक स्कूल, गणेश नगर, कोटा में स्थित है। उक्त विद्यालय का वातावरण स्वच्छ व साफ है तथा सफाई की अनुकूल व्यवस्था है। यह प्रमाण पत्र एक वर्ष के लिये मान्य होगा।


6/3/25
स्वास्थ्य अधिकारी

नगर निगम, कोटा
नगर निगम कोटा दक्षिण


Principal
BANSAL PUBLIC SCHOOL
Ganesh Nagar, KOTA (Raj.)


Secretary
Bansal Public School
Educational Society, Kota

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Abhishek Chandel Jain (AEN PHED Sub Div-I Kota)

(Name of Officers with designation) from Teachers Colony PHED

inspected the BANSAL PUBLIC SCHOOL, Ganesh Nagar - KOTA

(Name & Address of the school) on 16/12/2024 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. Lab. Tech. (Chem.) 2024-25/1590 dated 23/12/2024

of PHED Regional Lab. Akolgarh-KOTA (PHED Lab) certified that the

BANSAL PUBLIC SCHOOL - KOTA (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till June - 2025

Signature with Seal:

Name

Designation


Name & Address of the Office / Department :

To

Bansal Public School
Ganesh Nagar, Near Medical College - KOTA
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies


Principal
BANSAL PUBLIC SCHOOL
Ganesh Nagar, KOTA (Raj.)


Secretary
Bansal Public School
Educational Society, Kota

OFFICE OF THE SENIOR CHEMIST

Public Health Engineering Department, Regional Laboratory, Kota
Test Report (Chemical Examination of Water)



No.Lab./Tech.(Chem)/2024-25/ 1590

To,

**Bansal Public School
Ganesh Nagar, Kota**

Date- 23/12/24

District- Kota

Sample taken by- Mahendra Kumar Verma

Ref.No./ Date-N.M. Date 16.12.24

Date of Receipt- 16.12.24

Sample Not Collected by Lab

Source	Permissible Value as per IS : 10500/2012		School Water Tap R.O.
Location			Bansal Public School Ganesh Nagar
Village/Town/City			Kota
Date of Collection			16.12.24
Date of Examination			18.12.24
Sample No	Desirable Limit	Permissible limit in absence of alternate Source	PC-193
Note:- All results except pH are in mg/L			
pH	6.5 to 8.5	No relaxation	7.80
Turbidity(NTU)	1	5	0.67
Colour	5	15	-
Odour	Agreeable	Agreeable	-
Total Alkalinity (as CaCO_3)	200	600	24
Total Hardness (as CaCO_3)	300	600	92
Chloride (as Cl^-)	250	1000	32
Nitrate (as NO_3^-)	45	45	3
Fluoride (as F^-)	1.0	1.5	0.0070
Total Dissolved Solids	500	2000	136

Senior Chemist
PHED Reg. Laboratory Kota

No.Lab./Tech.(Chem)/2024-25/

Copy To :

Date:-

1. Chief Chemist, PHED Rajasthan, Gandhi Nagar, Jaipur

Senior Chemist
PHED Reg. Laboratory Kota

Principal
**BANSAL PUBLIC SCHOOL
Ganesh Nagar, KOTA (Raj.)**

Secretary
Bansal Public School
Educational Society, Kota

OFFICE OF THE SENIOR CHEMIST
Public Health Engineering Department Regional Laboratory
AKELGARH KOTA - 324010 (Raj.)
BACTERIOLOGICAL EXAMINATION OF WATER

PHED/Lab./Sr. Chemist/Bact./2024.2025.1590

Date : 23/12/24

To,

Tehsil : Laalpura

The..... Bansal Public School.....

District : Kota

..... Ganesh Nagar,

Village : Kota

..... Kota,

Reference..... N.M. / 16.12.24

Code No. : U

Name of Sample Taker. Sh. Mahendra Kumar Verma

Sample Not Collected by Lab

Lab Sample Number	Date & Time of Collection	Date of Exam.	Residual Chlorine Mg/Lit.	Source	PARTICULARS OF SAMPLE	Coliform organism MPN/100 ML.	E coli organism MPN/100 ML.
PB-131	16-12-24	16-12-24 to 18-12-24	-	RO	Bansal Public School, Ganesh Nagar, Kota	Nil	

Principal
BANSAL PUBLIC SCHOOL
Ganesh Nagar, KOTA (Raj.)

Secretary
 Bansal Public School
 Educational Society, Kota

Senior Chemist
 P.H.E.D. Regional Lab. Kota

PHED/Lab./Sr. Chemist/Bact./2024.....- 2025.....

Date

- Copy to (1) S.E., P.H.E.D., Circle, Kota
 (2) Ex. En. P.H.E.D., Div.....
 (3)

Senior Chemist
 P.H.E.D. Regional Lab. Kota