




## कार्यालय नगर निगम कोटा दक्षिण (राज०)

क्रमांक :- ननिको(द.) / जनस्वा. / 2024 / 1156

दिनांक :- 26/2/2024

### प्रमाण-पत्र

प्रमाणित किया जाता है कि बंसल पब्लिक स्कूल, गणेश नगर, कोटा में स्थित है। उक्त विद्यालय का वातावरण स्वच्छ व साफ है तथा सफाई की अनुकूल व्यवस्था है। यह प्रमाण पत्र एक वर्ष के लिये मान्य होगा।

  
26/2/2024

स्वास्थ्य अधिकारी  
नगर निगम, कोटा दक्षिण  
नगर निगम कोटा दक्षिण



**OFFICE OF THE SENIOR CHEMIST**  
Public Health Engineering Department, Regional Laboratory, Kota  
**Test Report (Chemical Examination of Water)**

No.Lab./Tech.(Chem)/2023-24/ 2058 *Sample Not Collected by Lab* Date:- 05/3/24  
To,

**The Principal  
Bansal Public school  
Ganesh Nagar , Kota**

District- Kota

Reference No./ Date- Not Mentioned / 26.02.2024  
Date of Receipt- 26.02.2024

Sample taken by- Mahendra Kumar Verma

Source	Permissible Value as per IS :		R.O. Water
Location	10500/2012		At Bansal Public School Campus Ganesh Nagra Kota
Village/Town/City			Kota
Date of Collection			26.02.2024
Date of Examination			28.02.2024
Sample No	Desirable Limit	Permissible limit in absence of alternate Source	PC-174
<b>Note:- All results except pH are in mg/L</b>			
pH	6.5 to 8.5	No relaxation	7.28
Turbidity(NTU)	1	5	0.10
Colour	5	15	-
Odour	Agreeable	Agreeable	-
Total Alkalinity ( as CaCO <sub>3</sub> )	200	600	68
Total Hardness ( as CaCO <sub>3</sub> )	300	600	96
Chloride as ( Cl <sup>-</sup> )	250	1000	36
Nitrate as ( NO <sub>3</sub> <sup>-</sup> )	45	45	2
Fluoride as ( F <sup>-</sup> )	1.0	1.5	0.113
Total Dissolved Solids	500	2000	205

**REPORT IS NOT VALID FOR  
JUDICIAL AND COMMERCIAL  
PURPOSE**

*(Signature)*  
Senior Chemist  
PHED Reg. Laboratory Kota

No.Lab./Tech.(Chem)/2023-24/

Date:-

Copy To :

1. Chief Chemist, PHED Rajasthan, Gandhi Nagar, Jaipur

*(Signature)*  
Senior Chemist  
PHED Reg. Laboratory Kota

**OFFICE OF THE SENIOR CHEMIST**  
**Public Health Engineering Department Regional Laboratory**  
**AKELGARH KOTA - 324010 (Raj.)**  
**BACTERIOLOGICAL EXAMINATION OF WATER**

PHED/Lab./Sr. Chemist/Bact./2024..20.25.. / 32

Date : 08/4/24

To,  
 The... Principal,.....  
     Bansal Public School.....  
     Ganesh Nagar, Kota......

Tehsil : Lasdpura

District : Kota

Village : Kota


Reference... NM/2.4.24.....

Code No. : U

Name of Sample Taker... Sh. Mahendra Kumar Verma.

Sample Not Collected by Lat

Lab Sample Number	Date & Time of Collection	Date of Exam.	Residual Chlorine Mg/Lit.	Source	PARTICULARS OF SAMPLE	Coliform organism MPN/100 ML.	E coli organism MPN/100 ML.
PB-03	2.4.24	2.4.24 to 4.4.24	-	RO	School Campus	Nil	

  
**Senior Chemist**  
 P.H.E.D. Regional Lab. Kota

PHED/Lab/Sr. Chemist/Bact/2024..... - 2025..... Date

- Copy to (1) S.E., P.H.E.D., Circle, Kota  
 (2) Ex. En. P.H.E.D., Div.....  
 (3) .....

**Senior Chemist**  
 P.H.E.D. Regional Lab. Kota